



STATE LEVEL ENVIRONMENT IMPACT ASSESSMENT AUTHORITY

Environment department,
Room No. 217, 2nd floor,
Mantralaya, Annexe,
Mumbai- 400 032.
Date: July 20, 2021

To,
Mr. Sanjay Tyagi
at Sr. No. 11/7, 11/8, 11/9 -Part & 11/2

Subject: Environment Clearance for Sai Mystique by M/s Sai Shree Developers

Sir,

This has reference to your communication on the above mentioned subject. The proposal was considered as per the EIA Notification - 2006, by the State Level Expert Appraisal Committee-III, Maharashtra in its 84th meeting and recommend the project for prior environmental clearance to SEIAA. Information submitted by you has been considered by State Level Environment Impact Assessment Authority in its 173rd meetings.

2. It is noted that the proposal is considered by SEAC-III under screening category 8(a) as per EIA Notification 2006.

Brief Information of the project submitted by you is as below :-


1.Name of Project	Sai Mystique
2.Type of institution	TOR
3.Name of Project Proponent	Mr.Sanjay Tyagi
4.Name of Consultant	Sneha Hi-Tech Products
5.Type of project	Housing Project
6.New project/expansion in existing project/modernization/diversification in existing project	Expansion
7.If expansion/diversification, whether environmental clearance has been obtained for existing project	Environmental clearance has been obtained for the existing project vide letter no SEAC-2010/CR-871/TC-2 dated 30th June 2011.
8.Location of the project	Sr. No. 11/7, 11/8, 11/9 -Part & 11/2
9.Taluka	Haveli
10.Village	Ambegaon(Bk)
Correspondence Name:	Mr.Sunil Baraskar
Room Number:	"Survey Nos. 11/7, 11/8, 11/9 -Part & 11/2,
Floor:	Behind Ashok Leyland Co.
Building Name:	Near Sinhgad Institute, Ambegaon(BK)
Road/Street Name:	Haveli
Locality:	Ambegaon
City:	Pune
11.Whether in Corporation / Municipal / other area	Pune Municipal Corporation
12.IOD/IOA/Concession/Plan Approval Number	Not Applicable IOD/IOA/Concession/Plan Approval Number: Collector Sanction:PRH / NASR / 949 / 2014 DT:- 09 / 10 / 2014 ; Town Planning :N. A. BP / MOUJE AMBEGOAN BK. / TAL. HAVELI, S.NO. 11/2,11/7 & 11/8(pt) & 11/9 / S.S.P / 3156 DATE :- 02 / 06 / 2014. Approved Built-up Area: 22944.48

SEIAA Meeting No: 173 Meeting Date: August 1, 2019 (SEIAA-STATEMENT-000001275)
SEIAA-MINUTES-000002609
SEIAA-EC-000002359

Page 1 of 13

Manisha Patankar Mhaiskar (Member Secretary SEIAA)

13.Note on the initiated work (If applicable)	We have carried out the construction on site as per the EC received vide letter no SEAC-2010/CR.871/TC-2 dated 30th June 2011.
14.LOI / NOC / IOD from MHADA/ Other approvals (If applicable)	Not Applicable
15.Total Plot Area (sq. m.)	25000
16.Deductions	3750
17.Net Plot area	21250
18 (a).Proposed Built-up Area (FSI & Non-FSI)	FSI area (sq. m.): 22944.48
	Non FSI area (sq. m.): 25086.02
	Total BUA area (sq. m.): 48030.5
18 (b).Approved Built up area as per DCR	Approved FSI area (sq. m.): 22944.48
	Approved Non FSI area (sq. m.): 25086.02
	Date of Approval: 06-02-2014
19.Total ground coverage (m2)	2858.61
20.Ground-coverage Percentage (%) (Note: Percentage of plot not open to sky)	13.45%
21.Estimated cost of the project	982000000



Government of Maharashtra


Manisha Patankar Mhaiskar

22. Production Details

Serial Number	Product	Existing (MT/M)	Proposed (MT/M)	Total (MT/M)
1	Not applicable	Not applicable	Not applicable	Not applicable

23. Total Water Requirement

Dry season:	Source of water	Pune Municipal Corporation		
	Fresh water (CMD):	185		
	Recycled water - Flushing (CMD):	92		
	Recycled water - Gardening (CMD):	14		
	Swimming pool make up (Cum):	2		
	Total Water Requirement (CMD) :	292		
	Fire fighting - Underground water tank(CMD):	350		
	Fire fighting - Overhead water tank(CMD):	180		
	Excess treated water	134		
Wet season:	Source of water	Pune Municipal Corporation		
	Fresh water (CMD):	185		
	Recycled water - Flushing (CMD):	92		
	Recycled water - Gardening (CMD):	00		
	Swimming pool make up (Cum):	2		
	Total Water Requirement (CMD) :	279		
	Fire fighting - Underground water tank(CMD):	350		
	Fire fighting - Overhead water tank(CMD):	180		
	Excess treated water	148		
Details of Swimming pool (If any)	--			



24.Details of Total water consumed

Particulars	Consumption (CMD)			Loss (CMD)			Effluent (CMD)		
	Existing	Proposed	Total	Existing	Proposed	Total	Existing	Proposed	Total
Domestic	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable

25.Rain Water Harvesting (RWH)	Level of the Ground water table:	Pre-Monsoon:15-20 m BGL;Post Monsoon:6-8 m BGL
	Size and no of RWH tank(s) and Quantity:	No of RWH Tanks:2;Quantity:100 m3 each
	Location of the RWH tank(s):	As per the services layout
	Quantity of recharge pits:	8
	Size of recharge pits :	3 recharge pits of size 6.5 m x 5.0 m x1.35 m ;1 recharge pit of size 6.5 m x 4 m x 1.35 m;1 recharge pit of size 4.5 m x 4 m x 1.35 m;3 recharge pits of size 2m x 2m x2m
	Budgetary allocation (Capital cost) :	Rs.13 Lakhs
	Budgetary allocation (O & M cost) :	Rs.1.3 Lakh
	Details of UGT tanks if any :	Total water capacity:628 m3/day Firewater Tank: 350 m3/day Domestic water Tank:278.5 m3/day Flushing water Tank:139.25 m3/day


26.Storm water drainage	Natural water drainage pattern:	North to South
	Quantity of storm water:	1040 m ³ /hr
	Size of SWD:	600 mm

27.Sewage and Waste water	Sewage generation in KLD:	241
	STP technology:	DTAS and MBBR
	Capacity of STP (CMD):	No.of STP:2;Capacity of STP :STP-1: 208 KLD; STP-2: 50 KLD
	Location & area of the STP:	Location of STP 1: Westside ; Location of STP 2 :South side ;STP 1- 130 sqm; STP 2- 33.26 sqm; TOTAL -163.26 sqm
	Budgetary allocation (Capital cost):	Rs.80.25 Lakhs
	Budgetary allocation (O & M cost):	Rs.16.23 Lakhs/annum

28.Solid waste Management

Waste generation in the Pre Construction and Construction phase:	Waste generation:	13 kg/day
	Disposal of the construction waste debris:	This material shall be used for back filling and leveling of the plot and remaining will be disposed to authorized sites
Waste generation in the operation Phase:	Dry waste:	413 Kg/day
	Wet waste:	619 Kg/day
	Hazardous waste:	Negligible
	Biomedical waste (If applicable):	Not Any
	STP Sludge (Dry sludge):	45 Kg/day
	Others if any:	Not Any
Mode of Disposal of waste:	Dry waste:	Dry waste will be handed over to SWACH.
	Wet waste:	Wet waste will be treated in OWC.
	Hazardous waste:	Will be handed over to authorized vendors.
	Biomedical waste (If applicable):	Not Any
	STP Sludge (Dry sludge):	Will be used as manure for landscaping
	Others if any:	Not Any
Area requirement:	Location(s):	North Side
	Area for the storage of waste & other material:	15 sqm
	Area for machinery:	60 sqm
Budgetary allocation (Capital cost and O&M cost):	Capital cost:	Rs.25.75 Lakhs
	O & M cost:	Rs.7.60 Lakhs/annum

Government of
Maharashtra



29. Effluent Characteristics

Serial Number	Parameters	Unit	Inlet Effluent Characteristics	Outlet Effluent Characteristics	Effluent discharge standards (MPCB)
1	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable
Amount of effluent generation (CMD):		Not applicable			
Capacity of the ETP:		Not applicable			
Amount of treated effluent recycled :		Not applicable			
Amount of water send to the CETP:		Not applicable			
Membership of CETP (if require):		Not applicable			
Note on ETP technology to be used		Not applicable			
Disposal of the ETP sludge		Not applicable			



Government of Maharashtra

Manisha Patankar Mhaiskar

30.Hazardous Waste Details							
Serial Number	Description	Cat	UOM	Existing	Proposed	Total	Method of Disposal
1	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable
31.Stacks emission Details							
Serial Number	Section & units	Fuel Used with Quantity	Stack No.	Height from ground level (m)	Internal diameter (m)	Temp. of Exhaust Gases	
1	200 kVA	HSD-34.6 Litres/day	1	3	0.12	543 degree Celcius	
32.Details of Fuel to be used							
Serial Number	Type of Fuel	Existing	Proposed	Total			
1	HSD	Not applicable	HSD	HSD			
33.Source of Fuel		Authorised Vendor					
34.Mode of Transportation of fuel to site		By road					
35.Energy							
Power requirement:	Source of power supply :	MSEDCL					
	During Construction Phase: (Demand Load)	33 KW					
	DG set as Power back-up during construction phase	1 x 40 KVA					
	During Operation phase (Connected load):	1863.47 KW					
	During Operation phase (Demand load):	1012.89 KVA					
	Transformer:	2 x 630KVA					
	DG set as Power back-up during operation phase:	1 x 200 KVA					
	Fuel used:	HSD					
	Details of high tension line passing through the plot if any:	Not Applicable					
Energy saving by non-conventional method:							

1. Timers and contractors will be used to switch on / off common are & external landscape and facade lighting.
2. LED fittings will be used for corridors, Lobbies and common areas.
3. Energy efficient LED lamps which give approx. 30% more light output for the same watts consumed and therefore require less nos. Of fixtures and corresponding lower point
4. All cables will be derated to avoid heating during use. This also indirectly reduces losses and improves reliability. To achieve the same we have considered current carrying capacity of all the cables laid through ground/air whichever is minimum.
5. 125 Ltrs Solar water is provided for each flat.
6. Solar PV panel system is proposed for Street lighting & Building common load.

36. Detail calculations & % of saving:

Serial Number	Energy Conservation Measures	Saving %
1	Timers and contractors will be used to switch on / off common are & external landscape and facade lighting. LED fittings will be used for corridors, Lobbies and common areas. Energy efficient LED lamps which give approx. 30% more light output for the same watts consumed and therefore require less nos. Of fixtures and corresponding lower point .All cables will be derated to avoid heating during use. This also indirectly reduces losses and improves reliability. To achieve the same we have considered	40%
2	125 Ltrs Solar water is provided for each flat.	82 %
3	Solar PV panel system is proposed for Street lighting & Building common load.	23%

37. Details of pollution control Systems

Source	Existing pollution control system	Proposed to be installed
STP	208 m3/day	50 m3/day
OWC	--	1 OWC proposed
DG Sets	--	1 x 200 KVA
Budgetary allocation (Capital cost and O&M cost):	Capital cost:	Rs.72.31 Lakhs
	O & M cost:	Rs.6.63 Lakhs/annum

38. Environmental Management plan Budgetary Allocation

a) Construction phase (with Break-up):

Serial Number	Attributes	Parameter	Total Cost per annum (Rs. In Lacs)
1	Air Environment	Water For Dust Suppression	0.72
2	Air Environment	Air & Noise monitoring	0.96
3	Air Environment	Air & Noise monitoring	0.96
4	Water Environment	Water monitoring	0.36
5	Land Environment	Site Sanitation	0.5
6	Land Environment	Site Sanitation	0.5
7	Socio- Economic Environment	Disinfection- Pest Control	1.8

b) Operation Phase (with Break-up):

Serial Number	Component	Description	Capital cost Rs. In Lacs	Operational and Maintenance cost (Rs. in Lacs/yr)
---------------	-----------	-------------	--------------------------	---

1	Environmental Monitoring	Ambient Air quality, Noise Level, Exhaust from DG Set, Drinking Water, Sewage from STP, As per EP act, Manure	--	15.0
2	Water	RWH	13.00	1.3
3	Water	STP	80.25	16.23
4	Energy	Solar PV Cells	6.00	0.30
5	Energy	Solar Hot water	66.31	6.33
6	Land Environment	Gardening	12.59	2.6
7	Solid waste	OWC	25.75	7.60
8	Total	--	203.9	49.36


39.Storage of chemicals (inflammable/explosive/hazardous/toxic substances)

Description	Status	Location	Storage Capacity in MT	Maximum Quantity of Storage at any point of time in MT	Consumption / Month in MT	Source of Supply	Means of transportation
Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable	Not applicable

40.Any Other Information

No Information Available

Government of
Maharashtra



	CRZ/ RRZ clearance obtain, if any:	Not Applicable
	Distance from Protected Areas / Critically Polluted areas / Eco-sensitive areas/ inter-State boundaries	None in 10 Km.
	Category as per schedule of EIA Notification sheet	8(a)
	Court cases pending if any	Not Any
	Other Relevant Informations	---
	Have you previously submitted Application online on MOEF Website.	Yes
	Date of online submission	13-09-2017

3. The proposal has been considered by SEIAA in its 173rd meeting & decided to accord environmental clearance to the said project under the provisions of Environment Impact Assessment Notification, 2006 subject to implementation of the following terms and conditions:

Specific Conditions:

I	The committee noted that Cost of remediation plan and natural & community resource augmentation plan as per revised approach paper is estimated as Rs. 1,98,00,000/-. The Committee also noted that the amount of CER as per MoEF & CC circular dated 1/05/2018 is Rs. 16,00,000/- which is less than the remediation / augmentation plan. Therefore committee decided to obtain Bank Guarantee of Rs 1.98 Crore for the project completion period.
II	PP Shall comply with Standard EC conditions mentioned in the Office Memorandum issued by MoEF & CC vide F.No.22-34/2018-IA.III dt.04.01.2019.
III	PP to submit a bank guarantee of Rs. 1.98 Cr to Maharashtra Pollution Control Board towards effective implementation of the remediation plan and Natural and Community Resource Plan.

General Conditions:

I	This EC is issued subject to the condition that the implementation of EMP, remediation plan and Natural and Community Resource Plan will be completed during the period for which the Bank Guarantee is given, otherwise the BG should be suitably extended up to implementation of EMP.
----------	--


**Government of
Maharashtra**

II

a) Construction Phase :- I. The solid waste generated should be properly collected and segregated. Dry/inert solid waste should be disposed of to the approved sites for land filling after recovering recyclable material. II. Disposal of muck, Construction spoils, including bituminous material during construction phase should not create any adverse effect on the neighbouring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in the approved sites with the approval of competent authority. III. Any hazardous waste generated during construction phase should be disposed off as per applicable rules and norms with necessary approvals of the Maharashtra Pollution Control Board. IV. Adequate drinking water and sanitary facilities should be provided for construction workers at the site. Provision should be made for mobile toilets. The safe disposal of wastewater and solid wastes generated during the construction phase should be ensured. V. Arrangement shall be made that waste water and storm water do not get mixed. VI. Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices. VII. The ground water level and its quality should be monitored regularly in consultation with Ground Water Authority. VIII. Permission to draw ground water for construction of basement if any shall be obtained from the competent Authority prior to construction/operation of the project. IX. Fixtures for showers, toilet flushing and drinking should be of low flow either by use of aerators or pressure reducing devices or sensor based control. X. The Energy Conservation Building code shall be strictly adhered to. XI. All the topsoil excavated during construction activities should be stored for use in horticulture / landscape development within the project site. XII. Additional soil for levelling of the proposed site shall be generated within the sites (to the extent possible) so that natural drainage system of the area is protected and improved. XIII. Soil and ground water samples will be tested to ascertain that there is no threat to ground water quality by leaching of heavy metals and other toxic contaminants. XIV. PP to strictly adhere to all the conditions mentioned in Maharashtra (Urban Areas) Protection and Preservation of Trees Act, 1975 as amended during the validity of Environment Clearance. XV. The diesel generator sets to be used during construction phase should be low sulphur diesel type and should conform to Environments (Protection) Rules prescribed for air and noise emission standards. XVI. PP to strictly adhere to all the conditions mentioned in Maharashtra (Urban Areas) Protection and Preservation of Trees Act, 1975 as amended during the validity of Environment Clearance. XVII. Vehicles hired for transportation of Raw material shall strictly comply the emission norms prescribed by Ministry of Road Transport & Highways Department. The vehicle shall be adequately covered to avoid spillage/leakages. XVIII. Ambient noise levels should conform to residential standards both during day and night. Incremental pollution loads on the ambient air and noise quality should be closely monitored during construction phase. Adequate measures should be made to reduce ambient air and noise level during construction phase, so as to conform to the stipulated standards by CPCB/MPCB. XIX. Diesel power generating sets proposed as source of backup power for elevators and common area illumination during construction phase should be of enclosed type and conform to rules made under the Environment (Protection) Act, 1986. The height of stack of DG sets should be equal to the height needed for the combined capacity of all proposed DG sets. Use low sulphur diesel is preferred. The location of the DG sets may be decided with in consultation with Maharashtra Pollution Control Board. XX. Regular supervision of the above and other measures for monitoring should be in place all through the construction phase, so as to avoid disturbance to the surroundings by a separate environment cell /designated person.

Government of Maharashtra

III	<p>Operation phase:- I. a) The solid waste generated should be properly collected and segregated. b) Wet waste should be treated by Organic Waste Converter and treated waste (manure) should be utilized in the existing premises for gardening. And, no wet garbage will be disposed outside the premises. c) Dry/inert solid waste should be disposed of to the approved sites for land filling after recovering recyclable material. II. E-waste shall be disposed through Authorized vendor as per E-waste (Management and Handling) Rules, 2016. III. a) The installation of the Sewage Treatment Plant (STP) should be certified by an independent expert and a report in this regard should be submitted to the MPCB and Environment department before the project is commissioned for operation. Treated effluent emanating from STP shall be recycled/ reused to the maximum extent possible. Treatment of 100% grey water by decentralized treatment should be done. Necessary measures should be made to mitigate the odour problem from STP. b) PP to give 100 % treatment to sewage /Liquid waste and explore the possibility to recycle at least 50 % of water, Local authority should ensure this. IV. Project proponent shall ensure completion of STP, MSW disposal facility, green belt development prior to occupation of the buildings. As agreed during the SEIAA meeting, PP to explore possibility of utilizing excess treated water in the adjacent area for gardening before discharging it into sewer line. No physical occupation or allotment will be given unless all above said environmental infrastructure is installed and made functional including water requirement. V. The Occupancy Certificate shall be issued by the Local Planning Authority to the project only after ensuring sustained availability of drinking water, connectivity of sewer line to the project site and proper disposal of treated water as per environmental norms. VI. Traffic congestion near the entry and exit points from the roads adjoining the proposed project site must be avoided. Parking should be fully internalized and no public space should be utilized. VII. PP to provide adequate electric charging points for electric vehicles (EVs). VIII. Green Belt Development shall be carried out considering CPCB guidelines including selection of plant species and in consultation with the local DFO/ Agriculture Dept. IX. A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards. X. Separate funds shall be allocated for implementation of environmental protection measures/EMP along with item-wise breaks-up. These cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes. XI. The project management shall advertise at least in two local newspapers widely circulated in the region around the project, one of which shall be in the Marathi language of the local concerned within seven days of issue of this letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the Maharashtra Pollution Control Board and may also be seen at Website at http://parivesh.nic.in XII. Project management should submit half yearly compliance reports in respect of the stipulated prior environment clearance terms and conditions in hard & soft copies to the MPCB & this department, on 1st June & 1st December of each calendar year. XIII. A copy of the clearance letter shall be sent by proponent to the concerned Municipal Corporation and the local NGO, if any, from whom suggestions/representations, if any, were received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent. XIV. The proponent shall upload the status of compliance of the stipulated EC conditions, including results of monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely; SPM, RSPM, SO₂, NO_x (ambient levels as well as stack emissions) or critical sector parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.</p>
IV	<p>General EC Conditions:- I. PP has to strictly abide by the conditions stipulated by SEAC & SEIAA. II. If applicable Consent for Establishment shall be obtained from Maharashtra Pollution Control Board under Air and Water Act and a copy shall be submitted to the Environment department before start of any construction work at the site. III. Under the provisions of Environment (Protection) Act, 1986, legal action shall be initiated against the project proponent if it was found that construction of the project has been started without obtaining environmental clearance. IV. The project proponent shall also submit six monthly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well as by e-mail) to the respective Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. V. The environmental statement for each financial year ending 31st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the respective Regional Offices of MoEF by e-mail. VI. No further Expansion or modifications, other than mentioned in the EIA Notification, 2006 and its amendments, shall be carried out without prior approval of the SEIAA. In case of deviations or alterations in the project proposal from those submitted to SEIAA for clearance, a fresh reference shall be made to the SEIAA as applicable to assess the adequacy of conditions imposed and to add additional environmental protection measures required, if any. VII. This environmental clearance is issued subject to obtaining NOC from Forestry & Wild life angle including clearance from the standing committee of the National Board for Wild life as if applicable & this environment clearance does not necessarily implies that Forestry & Wild life clearance granted to the project which will be considered separately on merit.</p>



4. The environmental clearance is being issued without prejudice to the action initiated under EP Act or any court case pending in the court of law and it does not mean that project proponent has not violated any environmental laws in the past and whatever decision under EP Act or of the Hon'ble court will be binding on the project proponent. Hence this clearance does not give immunity to the project proponent in the case filed against him, if any or action initiated under EP Act.

5. In case of submission of false document and non-compliance of stipulated conditions, Authority/ Environment Department will revoke or suspend the Environment clearance without any intimation and initiate appropriate legal action under Environmental Protection Act, 1986.


6. The Environment department reserves the right to add any stringent condition or to revoke the clearance if conditions stipulated are not implemented to the satisfaction of the department or for that matter, for any other administrative reason.

7. Validity of Environment Clearance: The environmental clearance accorded shall be valid as per EIA Notification, 2006, and amendments by MoEF&CC Notification dated 29th April, 2015.

8. In case of any deviation or alteration in the project proposed from those submitted to this department for clearance, a fresh reference should be made to the department to assess the adequacy of the condition(s) imposed and to incorporate additional environmental protection measures required, if any.

9. The above stipulations would be enforced among others under the Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management and Handling) Rules, 1989 and its amendments, the public Liability Insurance Act, 1991 and its amendments.

10. Any appeal against this Environment clearance shall lie with the National Green Tribunal (Western Zone Bench, Pune), New Administrative Building, 1st Floor, D- Wing, Opposite Council Hall, Pune, if preferred, within 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.



Manisha Patankar Mhaiskar (Member Secretary SEIAA)

Copy to:

1. SECRETARY MOEF & CC
2. IA- DIVISION MOEF & CC
3. MEMBER SECRETARY MAHARASHTRA POLLUTION CONTROL BOARD MUMBAI
4. REGIONAL OFFICE MOEF & CC NAGPUR
5. MUNICIPAL COMMISSIONER PUNE
6. MUNICIPAL COMMISSIONER SATARA
7. REGIONAL OFFICE MPCB PUNE
8. REGIONAL OFFICE MIDC PUNE
9. MAHARASHTRA STATE ELECTRICITY DISTRIBUTION CO. LTD
10. COLLECTOR OFFICE PUNE
11. COLLECTOR OFFICE SATARA
12. COLLECTOR OFFICE SOLAPUR

